

**Errata to Amended Final License Application**

**Attachment 2**

**Exhibit B  
Table 7.2-2**

**Yuba River Development Project**  
FERC Project No. 2246

November 2017

©2017, Yuba County Water Agency  
*All Rights Reserved*



**Table 7.2-2. Modeled generation and plant factors for New Colgate Powerhouse under the proposed Project Operations Model run.**

Water Year	Annual Generation (MWh)	Annual Generation (aMW)	Plant Capability (MW)	Plant Factor
1970	1,311,652	150	315	0.480
1971	1,554,443	177	315	0.560
1972	1,076,188	123	315	0.390
1973	1,409,207	161	315	0.510
1974	1,952,470	223	315	0.710
1975	1,353,597	154	315	0.490
1976	624,202	71	315	0.230
1977	374,003	43	315	0.140
1978	1,279,968	146	315	0.460
1979	989,226	113	315	0.360
1980	1,583,773	181	315	0.570
1981	721,770	82	315	0.260
1982	2,052,358	234	315	0.740
1983	2,038,576	233	315	0.740
1984	1,635,002	187	315	0.590
1985	752,460	86	315	0.270
1986	1,226,909	140	315	0.440
1987	593,313	68	315	0.210
1988	509,599	58	315	0.180
1989	1,036,085	118	315	0.380
1990	607,515	69	315	0.220
1991	625,646	71	315	0.230
1992	671,771	77	315	0.240
1993	1,410,077	161	315	0.510
1994	620,762	71	315	0.220
1995	1,811,936	207	315	0.660
1996	1,657,276	189	315	0.600
1997	1,394,637	159	315	0.510
1998	1,686,126	192	315	0.610
1999	1,539,181	176	315	0.560
2000	1,286,632	147	315	0.470
2001	565,437	65	315	0.200
2002	695,265	79	315	0.250
2003	1,272,936	145	315	0.460
2004	1,018,321	116	315	0.370
2005	1,058,561	121	315	0.380
2006	1,895,132	216	315	0.690
2007	795,054	91	315	0.290
2008	561,608	64	315	0.200
2009	778,525	89	315	0.280
2010	1,034,502	118	315	0.370
<b>Total<sup>1</sup></b>	<b>47,061,701</b>	<b>--</b>	<b>--</b>	<b>--</b>
<b>Minimum</b>	<b>374,003</b>	<b>42.7</b>	<b>--</b>	<b>0.140</b>
<b>Average<sup>1</sup></b>	<b>1,147,846</b>	<b>130.9</b>	<b>--</b>	<b>0.420</b>
<b>Median</b>	<b>1,076,188</b>	<b>122.8</b>	<b>--</b>	<b>0.390</b>
<b>Maximum</b>	<b>2,052,358</b>	<b>234.1</b>	<b>--</b>	<b>0.740</b>

Key: aMW = annual megawatt; MWh = megawatt-hour

<sup>1</sup> Totals and averages are calculated using unrounded values and may not sum correctly based on rounded values shown in the table.

**Table 7.2-2. Modeled generation and plant factors for New Colgate Powerhouse under the proposed Project Operations Model run.<sup>1</sup>**

Water Year	Annual Generation (MWh)	Annual Generation (aMW)	Plant Capability (MW)	Plant Factor
1970	1,311,652	150	315	0.48
1971	1,554,443	177	315	0.56
1972	1,076,188	123	315	0.39
1973	1,409,207	161	315	0.51
1974	1,952,470	223	315	0.71
1975	1,353,597	154	315	0.49
1976	624,202	71	315	0.23
1977	374,003	43	315	0.14
1978	1,279,968	146	315	0.46
1979	989,226	113	315	0.36
1980	1,583,773	181	315	0.57
1981	721,770	82	315	0.26
1982	2,052,358	234	315	0.74
1983	2,038,576	233	315	0.74
1984	1,635,002	187	315	0.59
1985	752,460	86	315	0.27
1986	1,226,909	140	315	0.44
1987	593,313	68	315	0.21
1988	509,599	58	315	0.18
1989	1,036,085	118	315	0.38
1990	607,515	69	315	0.22
1991	625,646	71	315	0.23
1992	671,771	77	315	0.24
1993	1,410,077	161	315	0.51
1994	620,762	71	315	0.22
1995	1,811,936	207	315	0.66
1996	1,657,276	189	315	0.60
1997	1,394,637	159	315	0.51
1998	1,686,126	192	315	0.61
1999	1,539,181	176	315	0.56
2000	1,286,632	147	315	0.47
2001	565,437	65	315	0.20
2002	695,265	79	315	0.25
2003	1,272,936	145	315	0.46
2004	1,018,321	116	315	0.37
2005	1,058,561	121	315	0.38
2006	1,895,132	216	315	0.69
2007	795,054	91	315	0.29
2008	561,608	64	315	0.20
2009	778,525	89	315	0.28
2010	1,034,502	118	315	0.37
<b>Total<sup>1</sup></b>	<b>47,061,701</b>	<b>--</b>	<b>--</b>	<b>--</b>
<b>Minimum</b>	<b>374,003</b>	<b>42.7</b>	<b>--</b>	<b>0.14</b>
<b>Average<sup>1</sup></b>	<b>1,147,846</b>	<b>130.9</b>	<b>--</b>	<b>0.42</b>
<b>Median</b>	<b>1,076,188</b>	<b>122.8</b>	<b>--</b>	<b>0.39</b>
<b>Maximum</b>	<b>2,052,358</b>	<b>234.1</b>	<b>--</b>	<b>0.74</b>

Key: aMW = annual megawatt; MWh = megawatt-hour

<sup>1</sup> Totals and averages are calculated using unrounded values and may not sum correctly based on rounded values shown in the table.